

	<b>Pemantauan HEPA Filter</b>	No : FKV008
		Revisi : 01
		Berlaku : 30 Jan 2020
		Hal. : 1 / 1

<b>Bidang</b> :	<b>Seksi</b> :
<b>Nama / Nomor Alat</b> :	<b>Bulan</b> :

Tgl	Pemantauan Pagi (08.00 – 09.00)	Paraf	Pemantauan Siang (13.00 – 14.00)	Paraf	Spv.	Keterangan
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						

Persyaratan :

Syarat	Min	Max
Action	100 Pa/10,197 mmH <sub>2</sub> O/0,015 Psi	500 Pa/50,987 mmH <sub>2</sub> O/ 0,073 Psi
Alert	110 Pa/11,217 mmH <sub>2</sub> O/ 0,016 Psi	450 Pa/49,889 mmH <sub>2</sub> O/ 0,065 Psi

Apabila terjadi penyimpangan di luar persyaratan,  
segera laporkan kepada Supervisor.

Asisten Manajer,