



Pemantauan Kondisi Filter Dispensing Booth

No : FQS032
 Revisi : 01
 Berlaku : 30 Jan 2020
 Hal. : 1 / 1

Bidang :	Seksi :
Nama / Nomor Ruangan :	Bulan :

Tgl	Pemantauan Pagi (08.00 – 09.00)		Paraf	Pemantauan Siang (13.00 – 14.00)		Paraf	Spv.	Keterangan
	HEPA	Medium		HEPA	Medium			
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								

Persyaratan :

	HEPA Filter				Medium Filter			
	Area Dispensing (mm Water)		Area Herbal (pa)		Area Dispensing (mm Water)		Area Herbal (pa)	
	Min	Max	Min	Max	Min	Max	Min	Max
Action	10	30	100	500	5	20	50	300
Alert	11	27	110	450	6	17	60	250

Apabila terjadi penyimpangan di luar persyaratan, segera laporkan kepada Supervisor

Asisten Manajer,